



CHINA CEPREI (SICHUAN) LABORATORY

## CERTIFICATE OF CONFORMITY

CERTIFICATE OF CONFORMITY is hereby issued to certify the following equipment

**Certificate Holder:** Sungrow Power Supply Co., Ltd.  
**Address:** No.2 Tianhu Road, High-Tech District, Hefei, Anhui,  
230088, P. R. China  
**Manufacturer:** Sungrow Power Supply Co., Ltd.  
**Address:** No.2 Tianhu Road, High-Tech District, Hefei, Anhui,  
230088, P. R. China

**Certification Marking:**



**Product Type:** Grid-Connected Inverter  
**Product Model:** WG30K3+SG30K3, WG20K3+SG20K3  
WG10K3+SG10K3  
**Parameters:** Input Voltage Range: 250VDC-800VDC  
Output Voltage Range: 330VAC-450VAC  
Rated Power: 30000W, 20000W, 10000W  
Output Rated Frequency: 50Hz & 60Hz  
**Certificate Number:** EU 01 031207 13  
**Test Report Number:** 252334967  
**Date of Issue:** April 8, 2009

Complied with the requirement set out by the Council Directive  
2004/108/EC (Electromagnetic Compatibility Directive).

The following standards were applied:

EN 61000-6-1: 2001, EN 61000-6-3: 2001  
EN 61000-3-2: 2000, EN 61000-3-3: 1995+A1:2001  
EN 61000-6-2: 2001, EN 61000-6-4: 2001, EN 55022: 1998+A2: 2003

Signature:



Oliver Deng

Title: Vice-General Manager

