



CHINA CEPREI (SICHUAN) LABORATORY

CERTIFICATE OF CONFORMITY

CERTIFICATE OF CONFORMITY is hereby issued to certify the following equipment

Certificate Holder: Sungrow Power Supply Co., Ltd.
Address: No.2 Tianhu Road, High-Tech District, Hefei, Anhui,
230088, P. R. China
Manufacturer: Sungrow Power Supply Co., Ltd.
Address: No.2 Tianhu Road, High-Tech District, Hefei, Anhui,
230088, P. R. China

Certification Marking:



Product Type: Grid-Connected Inverter
Product Model: WG50K3+SG50K3
Parameters: Input Voltage Range: 400VDC-850VDC
Output Voltage Range: 330VAC-450VAC
Rated Power: 50000W
Output Rated Frequency: 50Hz & 60Hz

Certificate Number: EU 02 031207 16
Test Report Number: 252334983
Date of Issue: April 8, 2009

Complied with the requirements set out by the Council Directive 2006/95/EC (Low Voltage Directive). The following standards were applied:

EN 50178: 1997, EN 60146-1-1: 1993+A1: 1997

Signature: _____



Title: Vice-General Manager _____

