



APPROVALS®

Certificate of Approval

Certificate No.: SAA111995

Date of Issue: 22 December 2011

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.


Certificate Holder: Sungrow Power Supply Co., Ltd.
No. 2, Tianhu Road,
New and High Technology Development Zone,
Hefei, Anhui 230088
P.R. China

Class Description: Non-Declared
Product Description: Grid-connected Solar Inverter
Brand Name: Sungrow
Model No.: SG4KTL-31
Markings: Input: 180-500Vdc, MPPT: 210-400Vdc,
Max 500Vdc, Max 20A IP65
Output: 230Vac 50Hz, Max 19A, 4000W
Standard: AS 4777.2:2005
AS 4777.3:2005
AS/NZS 3100:2009 Inc A1
Conditions: Nil

Approval Mark: SAA111995


Date First Registered: 22 December 2011

Date of Expiry: 22 December 2016


For and on Behalf of
SAA Approvals Pty Ltd



JAS-ANZ





APPROVALS®

Certificate of Approval

Addendum

Certificate No.: SAA111995

Date of Issue: 23 December 2011

Class Description: Non-Declared
Product Description: Grid-connected Solar Inverter

Additional Models

SG2K5TL-31

SG3KTL-31

Description

Similar to SG4KTL-31 except rated input MPPT 180-400Vdc, Max 15A and rated output 2500W 12A.

Similar to SG4KTL-31 except rated input MPPT 180-400Vdc, Max 18A and rated output 3000W 14A.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

JAS-ANZ

